



# CITY OF LODI

## COUNCIL COMMUNICATION

**AGENDA TITLE:** Specifications and Advertisement for Bids for Polemount and Padmount Transformers

**MEETING DATE:** April 17, 1996

**SUBMITTED BY:** Electric Utility Director

**RECOMMENDED ACTION:** That the City Council approve the specifications and authorize the advertisement for bids for nine 50KVA polemount transformers, and eleven three-phase padmount transformers of various classes and sizes.

**BACKGROUND INFORMATION:** This bid will consist of the following items:

Conventional Polemount Transformers

9 ea 50KVA 12,000V - 120/240V Secondary

Three-Phase Padmount Transformers

2 ea 112.5KVA 12,000VΔ - 208Y/120V Secondary

2 ea 150KVA 12,000VΔ - 208Y/120V Secondary

1 ea 300KVA 12,000VΔ - 208Y/120V Secondary

4 ea 300KVA 12,000VΔ - 480Y/277V Secondary

1 ea 750KVA 12,000VΔ - 480Y/277V Secondary

1 ea 1,500KVA 12,000VΔ - 480Y/277V Secondary

Some of the locations where transformers will be installed are the Hutchins Street Square Auditorium, McDonald's Restaurant, and the Well 4R/Watertank facility. Other units will be used to upgrade transformers in the downtown area, to replace PCB-contaminated units, or to replenish the Department's backup stock.

**FUNDING:** Electric Utility Department Operating Fund  
Estimated Cost: \$126,000

**BID OPENING:** May 22, 1996

Alan N. Vallow, Electric Utility Director

Prepared by Joel Harris, Purchasing Officer

APPROVED: \_\_\_\_\_

H. DIXON FLYNN  
City Manager